

Addendum #4

CR-437 Intersection with #4583 Wolf Branch Road and
Wallick Road Extension
Project No. 2010-01
Bid No. 10-0004

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-6 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

- Q. The only silt fence shown on the plans is at the pond area. Is that the only location required ?
- A. The contractor shall to bid to install silt fence along the right of way of the entire project.
- Q. Plan sheet 12 of 34 shows a 12' sidewalk trail on the north side of the roadway, while the typical section on sheet 33 of 34 shows 5' sidewalks on the north and south side of the roadway, which is correct?
- A. Bid to construct as per sheet #12 of the construction plans, installing the 12' sidewalk trail on the north side of the roadway.
- Q. The bid summary sheets for the CR 437 portion of the project do not have a bid item for 12" Stabilized subgrade, which is required for the Wallick Road portion of the project. The Wallick road summary sheets (separate sheets) do have a bid item for 12" Stabilized subgrade. In what Item do you want the subgrade included?
- A. On the CR-437 portion of the project bid to construct using 12" compacted subgrade as per the construction plans and on the Wallick Road portion of the project bid to construction using 12" stabilized subgrade.

Approved by:



Jeff Johnson, Construction Inspector Manager

9/25/09

Date

:smcd