


Addendum #5

CR-437 Intersection with #4583 Wolf Branch Road and
Wallick Road Extension
Project No. 2010-01
Bid No. 10-0004

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-6 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

- Q. Is there a number of calendar days you want this project completed in?
A. The contractor is to provide the number of days to complete the project. The bid amount and the number of completion days shall be considered when awarding the project.
- Q. In addendum #2 it states that two poles will be supplied by the county. It states that Pole #3 is longer than the pole shown on the plans can you please tell us how long this pole is and what the new depth for the foundation will be?
A. Pole #3 that Lake County will be supplying is 46' in length. Bid to install the pole an additional 2' in depth.

Approved by:



Jeff Johnson, Construction Inspector Manager

9/29/09

Date

:smcd