



**LAKE COUNTY**  
**FLORIDA**

OFFICE OF PROCUREMENT SERVICES  
315 WEST MAIN STREET, SUITE 441  
PO BOX 7800  
TAVARES FL 32778-7800

PHONE: (352) 343-9839  
FAX: (352) 343-9473

[www.lakegovernment.com](http://www.lakegovernment.com)

**ADDENDUM NO. 1**

**Addendum Date: May 8, 2014**  
**Request for Proposals ITB 14-0217**

**REPLACEMENT OF CENTRAL ENERGY PLANT BOILERS AT THE  
LAKE COUNTY DETENTION CENTER**

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid from being considered for award.

**This addendum does NOT change the date for receipt of bids or proposals.**

The purpose of this addendum is to note and provide a revised drawing M3. This revised drawing is marked as a revision. The revised drawing M3 replaces drawing M3 originally included in attachment 2 to the subject solicitation. The revised drawing has been added as a separate tab on the County webpage for the solicitation. The revision adds a 2" line for the 3<sup>rd</sup> water heater to pipe it up stream of the mixing valve, and a note about the recirculating tee connection as well.

Acknowledgement of receipt and understanding of this addendum:

Firm Name: \_\_\_\_\_ Date: \_\_\_\_\_  
Signature: \_\_\_\_\_ Title: \_\_\_\_\_  
Typed/Printed Name: \_ \_\_\_\_\_