

ADDENDUM #2

Thomas Avenue Sidewalk, FPN #431530-1-58-01
Project No. 2015-01
Bid No. 15-0002

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.


Questions Asked Via E-Mail

Q1: Sheet 9 sidewalk typical section shows 4" deep compacted Natural Sand Base material under the proposed sidewalk. What are the specifications for the natural Sand material? Is the county looking for the contractor to import such material from an approved source? Please clarify.

A1: Contractor shall use existing material as subgrade for the sidewalk. Any existing grass shall first be removed and properly disposed.



Paul Erickson, Construction Inspector I



Date