



LAKE COUNTY FLORIDA

OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 416
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 2

Date: August 18, 2009

BID No. 09-0426

DETENTION CENTER WATER HEATER REPLACEMENT

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Respondents shall acknowledge receipt of this addendum by completing this form and returning it with the response. Failure to acknowledge this addendum may preclude consideration of the bid proposal award.**

Q & A's:

Question 1: *The existing water piping is galvanized with Victaulic fittings, couplings, and valves. Can we install new copper piping and then transition back to the existing piping? Or do you have something else specified?*

RESPONSE: **Yes, you can use copper piping and transition back to the existing piping.**

Question 2: *You had an electrical contractor at the meeting. Do you want us to still provide the electrical for the new heater's?*

RESPONSE: **Yes, as per scope of work #4 (h), furnish and install all electrical and control needs for both Fulton units. The existing power feeds to the #4 boiler that is being replaced is 120VAC, 60Hz, 1 Ph, 20 Amp. The electrical requirements for the specified boilers is 120VAC, 60Hz, 1 Ph, 4 Amps each.**

Question 3: *You have an existing 12" vent penetration and was wanting to know if we could run both 4" vents through the existing vent pipe and then install a 12" cap with 2 – 4" vent terminations. Also, you have a large make-up air onto the plant. So it wouldn't be necessary to run 4" pipe up through the roof for make up air.*

RESPONSE: Yes, it is acceptable to use the existing piping 12” vent penetration to run both new vent pipes as long as this meets the requirements of the manufacturer installation specifications. The area is well vented to supply make up air for the new boilers.

Question 4: *If the answer is no to both questions in #3, can you let me know who the roofing contractor was for the plant building? I'd like to use them to avoid problems with warranty.*

RESPONSE: We anticipated that we would be able to use the existing vent penetrations for both the new boilers. If there is a need for additional penetrations, the roofing contractor was Anderson Shaw Roofing, Inc. of Florida.

END OF ADDENDUM #2

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____

"Earning Community Confidence Through Excellence in Service"

DISTRICT ONE
JENNIFER HILL

DISTRICT TWO
ELAINE RENICK

DISTRICT THREE
JIMMY CONNER

DISTRICT FOUR
LINDA STEWART

DISTRICT FIVE
WELTON G. CADWELL