

**Pre-Bid – Addendum #1**

#6611 Eagles Nest Road  
Project No. 2011-08  
Bid No. 12-0009.

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

A non-mandatory pre-bid meeting for the referenced project was held at 9:00 a.m. on September 29, 2011 in the Department of Public Works' conference room. The following were in attendance:

<b>Name</b>	<b>Company</b>	<b>Phone Number</b>	<b>Email Address</b>
Sara Boykin	Boykin Construction, Inc.	(352) 394-5993	<a href="mailto:boykinconst@aol.com">boykinconst@aol.com</a>
Lito Detorres	Professional Dirt Service	(352)589-7000	<a href="mailto:lito713@comcast.net">lito713@comcast.net</a>
Jennings Griffin	SSMC	(352)343-4880	<a href="mailto:jgriffin@ssmc.us">jgriffin@ssmc.us</a>
Laurie Henderson	J. Malever Construction	(352)429-9507	<a href="mailto:tomsmithjmc@embargmail.com">tomsmithjmc@embargmail.com</a>
Jeff Johnson	Lake County Public Works	(352)483-9024	<a href="mailto:jjohnson@lakecountyfl.gov">jjohnson@lakecountyfl.gov</a>
Matt Kennard	Paqco, Inc.	(352)365-0006	<a href="mailto:matt@paqcoinc.com">matt@paqcoinc.com</a>
Charlie Kent	Lake County Public Works	(352)787-0074	<a href="mailto:ckent@lakecountyfl.gov">ckent@lakecountyfl.gov</a>
Alan Kirkland	Lake County Public Works	(352) 483-9043	<a href="mailto:akirkland@lakecountyfl.gov">akirkland@lakecountyfl.gov</a>
Michelle Mangano	Art Walker Construction	(352)629-1466	<a href="mailto:michelle@artwalkerconstruction.com">michelle@artwalkerconstruction.com</a>
Sherry McDermott	Lake County Public Works	(352)483-9020	<a href="mailto:smcdermott@lakecountyfl.gov">smcdermott@lakecountyfl.gov</a>
Ron Rudolph	Lake County Public Works	(352)483-9021	<a href="mailto:rrudolph@lakecountyfl.gov">rrudolph@lakecountyfl.gov</a>
Terry Scott	Lake County Public Works	(352)483-9023	<a href="mailto:jscott@lakecountyfl.gov">jscott@lakecountyfl.gov</a>

This project is located in the Lady Lake area and shall consist of lowering #6611 Eagles Nest Road to improve its connection to US-27/441. The new construction for #6611 Eagles Nest Road shall consist of 12" type B stabilized subbase (40 LBR, 98% compaction), 10" limerock placed in two (2) 5" lifts (98% compaction each lift), primed and sanded, 2 1/2" minimum SP-12.5 asphaltic concrete, and 1" minimum 9.5 asphaltic concrete. Other work associated with this project shall include the following: Asphalt milling, thermoplastic striping, storm structure installation, gravity wall construction, swale work, roadway signage, sodding, and other miscellaneous incidental construction.


1. There is an existing 5 strand barbed wire fence located on the north side of Eagles Nest Road. The contractor shall bid to relocate this fence to an area just north of the new right of way line using the existing posts and gate. Include in your relocation bid the cost to replace the existing 5 strands of barbed wire; do not reuse the existing wire.
2. On the north side of Eagles Nest Road at approximately Sta. 32+75 the contractor shall bid to construct a driveway, 16' in width, to the right of way line. This driveway shall be constructed using 6" limerock, 98% compaction, 1" minimum SP 9.5 asphaltic concrete, and shall have a 15' radius.
3. Pay attention to all notes shown in the construction plans.
4. Work performed under this contract shall be based on a lump sum bid. Quantities, if shown in the bid, are estimated for bidding purposes only and shall be verified by the contractor.
5. The cost of all laboratory testing shall be borne by the county with the exception of the costs of failing tests and subsequent retests, which shall be borne by the contractor. Testing shall be in accordance with the FDOT Standard Specifications.

6. The contractor shall be responsible for notifying all utilities prior to construction and coordinating utility relocation with the project construction.
7. The Engineers Estimate is \$413,000.00.

Any questions shall be submitted in writing by **October 10, 2011** to Sherry McDermott via email at [smcdermott@lakecountyfl.gov](mailto:smcdermott@lakecountyfl.gov) and will be responded to through the issuance of an addendum. **Please be sure that all addendums are acknowledged by signing and dating the appropriate line on page W-4 of the bid proposal.** Addendums will be posted on Lake County's Procurement Services website. The website link for this project is provided below:

[http://www.lakecountyfl.gov/departments/county\\_manager/procurement\\_services/bid\\_details.aspx?bid\\_number=12-0009](http://www.lakecountyfl.gov/departments/county_manager/procurement_services/bid_details.aspx?bid_number=12-0009)

Approved by:

  
\_\_\_\_\_  
Jeff Johnson, Construction Inspection Manager

9/29/11  
\_\_\_\_\_  
Date

:smcd