

ADDENDUM #3

Wolf Branch Sink Drainage Improvements
Project No. 2016-01
Bid No. 16-0008

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

Questions Via E-Mail:

Q1: We are still trying to understand why a schedule of values is necessary if it's a lump sum bid?

A1: Please refer to the Bid Document which contains the instructions to bidders, general conditions, bid form, and other pertinent information for this project.

Q2: Will Lake County consider the use of Reinforced Concrete Pipe in place of A2000 for the drainage pipes 12" and larger?

A2: Lake County will accept Reinforced Concrete Pipe in place of A2000 for drainage pipes 15" and larger.



Heath McArdle, Construction Inspector II



Date